

सी इ पी सी आई प्रयोगशाला
एवं अनुसंधान संस्थान



CEPCI LABORATORY &
RESEARCH INSTITUTE

ACCREDITED AS PER
ISO / IEC 17025 : 2017



NABL Certificate No.
TC-6088

काश्चू भवन, मुन्टक्कल, कोल्लम- 691001, केरल, भारत. CIN:U74999KL1955NPL000300

Cashew Bhavan, Mundakkal, Kollam-691 001, Kerala, India, Tel:+91 474 2761003, 2742704
Fax: +91 474 2742704, E-mail:cepcilab@cashewindia.org Web: www.cepcilab.org.in

TEST CERTIFICATE
ORIGINAL

Date : 03 May 2021

ULR - TC608821000016553F

No : 1377

CUSTOMER ADDRESS	SAMPLE DETAILS
Name & Address : Sree narayana Public School & Junior College,Pavumba P.O.,Karunagappally.	Reg.No : CEPC/301/21-22 Customer Reference : Letter dated 28.04.2021 Sampling details : Direct Identification Code :
Other details if any :	Type of Sample : Well water Sample Description : Colourless liquid with tiny suspended particles Condition of the sample : Satisfactory Date of Receipt : 28 Apr 2021 Date of Starting : 28 Apr 2021 Date of Completion : 03 May 2021 Condition of packing : Unsealed plastic bottle


Table 1. Organoleptic and physical Parameters

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Colour ,Hazan Unit	Less than one	IS 3025 (part 4):2002	5
II	Odour	Agreeable	IS 3025 (part 5):2002	Agreeable
III	Total dissolved solids ,mg/l	70	IS 3025 (part 16):2002	500
IV	pH	7.2	IS 3025 (part 11):2002	6.5 -8.5

Table 2. General Parameters Concerning Substances Undesirable in Excessive Amounts

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Total Hardness (as CaCO ₃) ,mg/l	6.2	IS 3025 (Part21):1996	200

Page 1 of 2
MAYARANI.C.B
Assistant Principal Scientist



AUTHORISED SIGNATORY
AJINI. A.S
Scientist

- This Test Certificate refers only to the item tested
- This Certificate, if reproduced shall only be in full.
- Written approval of the Lab-in-charge is necessary for reproduction of this certificate